



CERTIFICATE OF APPROVAL
No CF 339

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
the undermentioned products of

EURO SPEC

Stancliffe Street, Millhill, Blackburn
Lancashire, BB2 2QR.
Tel: 01254 274100 Fax: 01254 274111

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT	TECHNICAL SCHEDULE
Euro Spec CEN, HIN, H2N, H3N, and SCH Series of Hinges	TS24 The Contribution of Single Axis Hinges to the Fire Resistance of Door Assemblies

Signed and sealed for and on behalf of CERTIFIRE

A handwritten signature in black ink, appearing to be "Sir Ken Knight".

Sir Ken Knight
Chairman - Management Council

Issued: 20th July 2005
Revised: 7th September 2011
Valid to: 6th September 2016

Page 1 of 7



Seal is in place Only valid when authentic CERTIFIRE



CERTIFICATE No CF 339
EURO SPEC

EURO SPEC CEN, HIN, H2N, H3N and SCH Series of Hinges

1. This approval relates to the use of the stated models of the CEN, HIN, H2N, H3N and SCH series hinges which are single axis hinges with square or radiused edges in contributing to the fire resistance performance of timber based doorsets, as defined by BS EN 1634-1, for periods of 30 and 60 minutes integrity. Subject to the undermentioned conditions, the doorsets would be expected to meet the relevant requirements of BS 5588 for doorsets when used in accordance with the provisions therein.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'
3. The hinges are approved on the basis of:
 - a) Initial type testing.
 - b) A design appraisal against TS24
 - c) Inspection and surveillance of factory production control
 - d) Certification of quality systems to ISO 9001:2008
 - e) Ongoing audit testing in accordance with BS EN 1935 requirements
4. The series of hinges comprise ranges of stainless and mild steel, single axis hinges, which may be for use on various classes of doorsets. The hinges are a minimum of Class 11 in accordance with BS EN 1935: 2002.
5. This certification relates to the following variants of hinges:

Hinge	Maximum Leaf Weight
H2N1202, H3N1104, H3N1101, HIN 13225	80 kg
H3N1103	100 kg
CEN 1433, CEN 1443, HIN 1433, HIN1443, H2N11015, H2N1102, H2N1103, H2N1424, H2N1435, H2N1446, H3N1207, H3N1208, HIN1433/HT, SCH14325, HIN 14325, H3N1102, HIN1433SEC, HIN1443SEC, SCH14325SEC, H2N1121	120 kg
	160 kg

6. This approval relates to the above hinge models incorporating various finishes.



CERTIFICATE No CF 339

EURO SPEC

EURO SPEC CEN, HIN, H2N, H3N and SCH Series of Hinges

7. This approval relates to the hinges CEN 1433, HIN 1433, HIN 13225, HIN 14325, HIN1433HT, HIN1433 SEC, SCH14325, SCH14325 SEC, H3N1207, H3N1104, H2N1435, H2N1446, H2N1103, H3N1102, H3N1208, H2N1202, H3N1101, H3N1103 and H2N1102 used with latched or unlatched single-leaf or double-leaf door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores and in timber frames (Codes TT and ITT) not less than 44 mm thick. The door frame shall consist of timber with a minimum density of 450 kg/m³ (with leaf to frame gaps less than 3mm), for FD20, FD30, E30 and EI30 applications.
8. This approval relates to the hinges CEN1433, HIN1433, HIN14325, CEN1443, HIN1443, HIN1443SEC, H2N1424, H2N11015, H2N1121, H3N1102, H3N1104, H3N1208, H2N1202, H3N1101, H3N1103, H2N1102, H2N1103, H3N1207, HIN1433/HT, SCH14325, HIN1433 SEC and SCH14325 SEC used with latched or unlatched single-leaf or double-leaf door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores with non-combustible sub-facings and in timber frames (Codes TT and ITT) not less than 52 mm thick. The door frame shall consist of timber with a minimum density of 650 kg/m³ (with leaf to frame gaps less than 3mm), for FD60, E60 and EI60 applications.
9. The CEN1433, HIN1433, HIN13225, HIN14325, HIN1433HT, HIN1433 SEC, SCH14325, SCH14325 SEC, H3N1207, H3N1104, H2N1435, H2N1446 and H2N1103 hinges must be bedded onto 1mm-thick Interdens or INT1433, INT1443 or INT1102 hinge liners (where appropriate), behind both blades for FD20, FD30, E30 and EI30 applications.
10. The H3N1102, H3N1208, H2N1202, H3N1101, H3N1103 and H2N1102 shall not require intumescent bedding for FD20, FD30, E30 and EI30 applications.
11. The CEN1443, HIN1443, HIN1443SEC, H2N1424, H2N11015 and H2N1121 hinges must be bedded onto 2mm-thick Interdens behind both blades for 60 minute applications. In addition to the Interdens, this hinge must also incorporate an additional Therm-A-Flex graphite based seal, 10mm x 4mm x 140mm-long positioned in the door frame rebate adjacent to the hinge, nearest to the frame stop for FD60, E60 and EI60 applications.
12. The CEN1433, HIN1433, HIN14325, HIN1433HT, HIN1433 SEC, SCH14325, SCH14325 SEC, H3N1207, H3N1104, H2N1103, H3N1102, H3N1208, H2N1202, H3N1101, H3N1103 and H2N1102 hinges must be bedded onto 2mm-thick Interdens behind both blades for FD60 applications. In addition to the Interdens, the door frame into which these hinges are to be fitted, must also incorporate 2No. 20mm x 4mm-thick Palusol based intumescent seal in PVC carrier rebated into the frame at the head for FD60, E60 and EI60 applications.
13. The above hinges may only be fitted to previously tested timber door assemblies when fitted in the manner described in this certificate and when particular aspects of the door assembly are maintained.
14. Hinges shall only be fitted using the fixings supplied by the hinge manufacturer.



CERTIFICATE No CF 339 EURO SPEC

EURO SPEC CEN, HIN, H2N, H3N and SCH Series of Hinges

15. The doorset, including door frame and associated building hardware, should be either CERTIFIRE approved for the relevant application and classification or the doorset, including door frame and associated building hardware, should have achieved at least 30 or 60 minutes fire resistance as required when tested, or subsequently assessed to BS 476: Part 22: 1987 or BS EN 1634-1. In either case regard should be paid to the maximum door mass permitted to be used with the hinge (see classification).
16. The doorset shall be installed in accordance with BS 8214: 2008.
17. The approval relates to on going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Matrix of acceptable doorsets and hinge types

Class	Approved Door Type						
	IMM	MM	TT	ITT	ITM	ITC	TM
FD20	x	x	✓	✓	x	x	x
FD30	x	x	x	✓	x	x	x
FD60	x	x	x	✓	x	x	x
FD120	x	x	x	x	x	x	x
FD240	x	x	x	x	x	x	x
E 20	x	x	✓	✓	x	x	x
EI 20	x	x	✓	✓	x	x	x
E 30	x	x	x	✓	x	x	x
EI 30	x	x	x	✓	x	x	x
E 60	x	x	x	✓	x	x	x
EI 60	x	x	x	✓	x	x	x
E 90	x	x	x	x	x	x	x
EI 90	x	x	x	x	x	x	x
E 120	x	x	x	x	x	x	x
EI 120	x	x	x	x	x	x	x
E 240	x	x	x	x	x	x	x
EI 240	x	x	x	x	x	x	x

NOTE: - CEN1443, HIN1443, HIN1443SEC, H2N1424, H2N11015 and H2N1121 are not approved for FD30, E30 and EI30 applications. HIN13225, H2N1435 and H2N1446 are not approved for FD60, E60 and EI60 applications.

Key: ✓ - approved
x - Not approved



CERTIFICATE No CF 339

EURO SPEC

EURO SPEC CEN, HIN, H2N, H3N and SCH Series of Hinges

Scope of Approval:

- The hinges may be fitted to doorsets without intumescent protection (seals) for up to 20 minutes integrity.
- All applications apply to glazed and unglazed doorsets.
- Both blades of the hinges CEN1433, HIN1433, HIN13225, HIN14325, HIN1433HT, HIN1433 SEC, SCH14325, SCH14325 SEC, H3N1207, H3N1104, H2N1435, H2N1446 and H2N1103 must be bedded onto 1mm-thick Interdens, INT1433, INT1443 or INT1102 hinge liners (where appropriate), when used with TT or ITT doorsets for FD20, FD30, E30 and EI30 applications.
- The H3N1102, H3N1208, H2N1202, H3N1101, H3N1103 and H2N1102 hinges do not require intumescent bedding for FD20, FD30, E30 and EI30 applications
- Both blades of the hinge CEN1443, HIN1443, HIN1443SEC, H2N1424, H2N11015 and H2N1121 must be bedded onto 2mm-thick Interdens when used with TT or ITT doorsets. In addition to the Interdens, this hinge must also incorporate an additional Therm-A-Flex graphite based seal, 10mm x 4mm x 140mm-long positioned in the door frame rebate adjacent to the hinge, nearest to the frame stop for FD60, E60 and EI60 applications.
- Both blades of the hinges CEN1433, HIN1433, HIN14325, HIN1433HT, HIN1433 SEC, SCH14325, SCH14325 SEC, H3N1207, H3N1104, H2N1103, H3N1102, H3N1208, H2N1202, H3N1101, H3N1103 and H2N1102 must be bedded onto 2mm-thick Interdens when used with TT or ITT doorsets for 60 minute applications. In addition to the Interdens, the door frame into which these hinges are to be fitted, must also incorporate 2No. 20mm x 4mm-thick Palusol based intumescent seal in PVC carrier rebated into the frame at the head for FD60, E60 and EI60 applications
- The door frame of TT and ITT doorsets shall consist of timber with a minimum density of 450 kg/m³ and 650 kg/m³ (with leaf to frame gaps less than 3mm) for 30 and 60 minute applications respectively.

A handwritten signature in black ink, appearing to be "K. J. ...", located below the "Page 5 of 7 Signed" text.



**CERTIFICATE No CF 339
EURO SPEC**

EURO SPEC CEN, HIN, H2N, H3N and SCH Series of Hinges

Classification codes

The above approval provides the following classifications:

H2N1202, H3N1104 and H3N1101 – Maximum leaf weight 80kg

3	7	4	1	1	3	0	11
----------	----------	----------	----------	----------	----------	----------	-----------

H2N1202 and HIN13225 – Maximum leaf weight 80kg

3	7	4	1	1	4	0	11
----------	----------	----------	----------	----------	----------	----------	-----------

H3N1103 – Maximum leaf weight 100kg

4	7	5	1	1	3	0	12
----------	----------	----------	----------	----------	----------	----------	-----------

H2N1102, H2N1103, H3N1102, H3N1207, H3N1208 and HIN1433
– Maximum leaf weight 120kg

4	7	6	1	1	3	0	13
----------	----------	----------	----------	----------	----------	----------	-----------

CEN1433, CEN1443, HIN1433, HIN1443, H2N11015, H2N1102, H2N1103, H2N1424,
H2N1435, H2N1446, H3N1207, H3N1208, HIN1433/HT, SCH14325 AND HIN14325
– Maximum leaf weight 120kg

4	7	6	1	1	4	0	13
----------	----------	----------	----------	----------	----------	----------	-----------



CERTIFICATE No CF 339
EURO SPEC

EURO SPEC CEN, HIN, H2N, H3N and SCH Series of Hinges

Classification codes (continued)

HIN1433SEC, HIN1443SEC and SCH14325SEC – Maximum leaf weight 120kg

4	7	6	1	1	4	1	13
----------	----------	----------	----------	----------	----------	----------	-----------

H2N1121 – Maximum leaf weight 160kg

4	7	7	1	1	4	0	14
----------	----------	----------	----------	----------	----------	----------	-----------

Further Information

Further information regarding the details contained in this data sheet may be obtained from Eurospec Architectural Hardware Limited (Tel: 01254 274100).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

A handwritten signature in black ink, appearing to be "K. P. ...".