



CERTIFICATE OF APPROVAL

No CF 5213

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

PROFAB ACCESS LIMITED

Unis C&D, Riversdale Road, Carlyon Road Ind Est,
Atherstone, Warwickshire, CV9 1LP
Tel: 01827 718222 Fax: 01827 818680

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

1000 Series Steel Based
Access Panel Doors

TECHNICAL SCHEDULE

TS30 Industrial Type Fire
Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 12th June 2014
Revised: 15th June 2020
Valid to: 24th September 2024





CERTIFICATE No CF 5213 PROFAB ACCESS LIMITED

1000 SERIES ACCESS PANEL DOORS

1. This approval relates to the use of the above access panel doors in providing fire resistance of up to 120 minutes integrity as defined in BS 476: Part 22: 1987 or BS EN 1634-1. Subject to the undermentioned conditions, the doors will meet the relevant requirements for fire resisting doorsets, for periods of up to 120 minutes (dependent upon orientation and size limitations) when used in accordance with the provisions therein.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The doors are approved on the basis of:
 - i) Initial Type Testing
 - ii) Audit testing at the frequency specified in TS30
 - iii) A design appraisal against TS30
 - iv) Inspection and surveillance of the Factory Production Control
4. This approval is applicable to single-acting, single and double leaf, latched doors, in the vertical and horizontal orientation, at leaf dimensions up to those given in Tables 1 and Table 2.
5. The door assemblies shall be mechanically fixed to wall/floor constructions having a fire resistance of at least the same period as the door assemblies.
6. This certificate does not include any approval relating to the mechanical requirements of the doors specified in TS30.
7. Labels to the CERTIFIRE design referencing Profab Access Limited, CERTIFIRE and CERTIFIRE Ref. No. CF5213 and the relevant fire resistance shall be affixed to each door in the prescribed position.
8. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name and mark together with the CERTIFIRE Certificate number and application where appropriate.



CERTIFICATE No CF 5213 PROFAB ACCESS LIMITED

1000 SERIES ACCESS PANEL DOORS

Table 1. Maximum Permitted Door Leaf Dimensions (Single leaf)

Configuration	Orientation	Period of Fire Resistance (minutes)	Maximum Door Leaf Height (mm)	Maximum Door Leaf Width (mm)	Maximum Door Area (m ²)
Single-acting, single-leaf, latched	Vertical	90	1495	745	1.11
	Vertical	120	1195	595	0.71
	Horizontal	90	1495	745	1.11
	Horizontal	120	1195	595	0.71

Table 2. Maximum Permitted Door Leaf Dimensions (Double leaf)

Configuration	Orientation	Period of Fire Resistance (minutes)	Maximum Door Leaf Height (mm)	Maximum Door Leaf Width (mm)	Maximum Door Area (m ²)
Single-acting, double-leaf, latched	Vertical	90	1495	445	1.11
	Vertical	120	1195	595	0.71
	Horizontal	60	1195	595	0.71

Note: Table 2, above, refers to the allowable dimensions of each leaf of an equal width double-leaf doorset. Unequal width double-leaf doorsets are also allowable but the slave leaf must be a minimum of 50% the width of the master leaf. The above maximum leaf dimensions also apply to unequal width leaves.

Further Information

Further information regarding the details contained in this data sheet may be obtained from Profab Access Limited (Tel: 01827 718222).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

J/134 E/163 J146

Page 3 of 3

Issued: 12th June 2014

Revised: 15th June 2020

Valid to: 24th September 2024