

---

**CERTIFICATE OF APPROVAL**  
**No CF 5253**

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

**PROFAB ACCESS LIMITED**

**Units C&D, Riversdale Road, Carlyon Road Ind Est,  
Atherstone, Warwickshire, CV9 1LP  
Tel: 01827 718222 Fax: 01827 818680**

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

**CERTIFIED PRODUCT**

**Steel Based Uninsulated Riser  
Doorsets**

**TECHNICAL SCHEDULE**

**TS30 Industrial Type Fire  
Resisting Doorsets**

**Signed and sealed for and on behalf of CERTIFIRE**



Sir Ken Knight  
Chairman - Management Council

Issued: 4<sup>th</sup> July 2014  
Valid to: 3<sup>rd</sup> July 2019

Page 1 of 3



---

## CERTIFICATE No CF 5253

### PROFAB ACCESS LIMITED

---

#### STEEL BASED UNINSULATED RISER DOORSETS

1. This approval relates to the use of the above riser doorsets in providing fire resistance of 60, 120 and 240 minutes integrity as defined in BS 476: Part 22: 1987 or BS EN 1634-1. Subject to the undermentioned conditions, the doors will meet the relevant requirements for fire resisting doorsets, for periods of up to 240 minutes (dependent upon size limitations) when used in accordance with the provisions therein.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section D of the Technical Standards (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'
3. The doors are approved on the basis of:
  - i) Initial type testing
  - ii) Audit testing at the frequency specified in TS30
  - iii) A design appraisal against TS30
  - iv) Inspection and surveillance of factory production control
6. This approval is applicable to single-acting, single and double-leaf, latched doorsets at leaf dimensions up to those given in Table 1.
7. The door assemblies shall be mechanically fixed to wall constructions having a fire resistance of at least the same period as the doorset.
8. This certificate does not include any approval relating to the mechanical requirements of the doors specified in TS30.
9. Doorsets shall be single-acting, single or double-leaf. Double-acting doorsets are not within the scope of this approval.
10. Labels to the CERTIFIRE design referencing Profab Access Limited, CERTIFIRE and CERTIFIRE Ref. No. CF5253 and the relevant fire resistance shall be affixed to each door in the prescribed position.

**CERTIFICATE No CF 5253  
PROFAB ACCESS LIMITED**

**STEEL BASED UNINSULATED RISER DOORSETS**

**Table 1. Maximum Permitted Door Leaf Dimensions**

Doorset Configuration	Integrity (minutes)	Maximum Door Leaf Height (mm)	Maximum Door Leaf Width (mm)	Maximum Door Area (m <sup>2</sup> )
Latched, single-acting, single or double-leaf	60	3120	1170	2.92
	120			
	240	2400	900	2.16

**Note:** There are no dimensional limitations when doorset are reduced in size from the above dimensions. Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

11. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name and mark together with the CERTIFIRE Certificate number (CF5253) and application where appropriate.

**Further Information**

Further information regarding the details contained in this data sheet may be obtained from Profab Access Limited (Tel: 01827 718222).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).