



CERTIFICATE OF APPROVAL

No CF 5833

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

PROFAB ACCESS LIMITED

Units C&D, Riversdale Road, Carlyon Road Ind Est,
Atherstone, Warwickshire, CV9 1FA
Tel: 01827 718222 Fax: 01827 818680

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

1500 Series Metal Based Riser
Doorsets

TECHNICAL SCHEDULE

TS30 Industrial Type Fire
Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 22nd November 2019
Valid to: 21st November 2024





CERTIFICATE No CF 5833 PROFAB ACCESS LIMITED

1500 SERIES METAL BASED RISER DOORSETS

1. This approval relates to the use of the above riser doorsets in providing fire resistance of 60, 90 and 120 minutes integrity as defined in BS 476: Part 22: 1987 or BS EN 1634-1. Subject to the undermentioned conditions, the doors will meet the relevant requirements for fire resisting doorsets, for periods of up to 120 minutes (dependent upon size limitations) when used in accordance with the provisions therein.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The doors are approved on the basis of:
 - i) Initial type testing
 - ii) Audit testing at the frequency specified in TS30
 - iii) A design appraisal against TS30
 - iv) Inspection and surveillance of factory production control
4. This approval is applicable to single-acting, single and double-leaf, latched doorsets at leaf dimensions up to those given in Table 1. Optionally; double leaf doorsets may contain leaves of unequal width provided that the narrower leaf has a width at least 44% that of the wider leaf.
5. The door assemblies shall be mechanically fixed to wall constructions having a fire resistance of at least the same period as the doorset.
6. This certificate does not include any approval relating to the mechanical requirements of the doors specified in TS30.
7. Doorsets shall be single-acting, single or double-leaf. Double-acting doorsets are not within the scope of this approval.
8. Labels to the CERTIFIRE design referencing Profab Access Limited, CERTIFIRE and CERTIFIRE Ref. No. CF5833 and the relevant fire resistance shall be affixed to each door in the prescribed position.

Signed
E/163

Issued: 22nd November 2019
Valid to: 21st November 2024

CERTIFICATE No CF 5833 PROFAB ACCESS LIMITED

1500 SERIES METAL BASED RISER DOORSETS

Table 1. Maximum Permitted Door Leaf Dimensions

Doorset Configuration	Integrity (minutes)	Maximum Door Leaf Height (mm)	Maximum Door Leaf Width (mm)	Maximum Door Area (m ²)
Latched, single-acting, single or double-leaf	60	2988	1118	3.34
	90			
	120	2629	983	2.58

Note: There are no dimensional limitations when doorset are reduced in size from the above dimensions. Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

Note: The dimensions given in the above table also apply to unequal width double leaf doorsets. The smaller leaf must be at least 44% the width of the master leaf.

9. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name and mark together with the CERTIFIRE Certificate number (CF5833) and application where appropriate.

Further Information

Further information regarding the details contained in this data sheet may be obtained from Profab Access Limited (Tel: 01827 718222).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Signed
E/163



Issued: 22nd November 2019
Valid to: 21st November 2024