



---

## CERTIFICATE OF APPROVAL

### No CF 689

---

This is to certify that, in accordance with  
TS00 General Requirements for Certification of Fire Protection Products  
The undermentioned products of

## BOSS DOOR CONTROLS

3 & 4 Rutherford Square, Brucefield Industry Park,  
Livingston, West Lothian, EH54 9BU  
Tel: 01506 467477 Fax: 01506 467478

Have been assessed against the requirements of the Technical Schedule(s)  
denoted below and are approved for use subject to the conditions  
appended hereto:

---

#### CERTIFIED PRODUCT

TS1.203, TS4.224, TS5.224,  
TS5.224V, TS5.225,  
TS5.225DA, TS5.225SA &  
TS5.226 Overhead Door  
Closers

#### TECHNICAL SCHEDULE

TS34 - The Contribution of  
Controlled Door Closing  
Devices and Accessories to  
Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan  
Certification Manager

Issued: 21st May 2009  
Reissued: 3<sup>rd</sup> July 2020  
Valid to: 2<sup>nd</sup> July 2025



## CERTIFICATE No CF 689 BOSS DOOR CONTROLS

### TS5.225SA & TS5.226

1. This approval relates to the following overhead mounted door closing devices and configurations:

	Link-arms			Slide arms			
	Projecting arm (Fig. 1) <i>Body door mounted on pull face</i>	Projecting arm (Fig. 61) <i>Body transom mounted on push face</i>	Parallel arm (Fig. 6) <i>Body door mounted on push face</i>	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
TS1.203	✓	✗	✗	✗	✗	✗	✗
TS4.224	✓	✗	✓	✗	✗	✗	✗
TS5.224	✓	✗	✓	✗	✗	✗	✗
TS5.224V	✓	✗	✓	✗	✗	✗	✗
TS5.225	✓	✗	✓	✗	✗	✗	✗
TS5.225DA	✓	✗	✗	✗	✗	✗	✗
TS5.225SA	✗	✗	✗	✓	✓	✗	✗
TS5.226	✓	✗	✓	✗	✗	✗	✗

**Key:** ✓ - approved                      ✗ - Not approved

*Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.*

2. This approval relates to their use with the following door assemblies: -

**Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (CERTIFIRE Code - ITT) as indicated in the individual model's approval matrix detailed later in this certificate.**

**Latched and unlatched, door assemblies consisting of metal faced and edged leaves in metal frames, fully-insulated for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240\* minutes (Codes MM & IMM) as indicated in the individual model's approval matrix detailed later in this certificate.**

\* See individual model's approval matrix for exact coverage of approval, fire resistance periods shown above do not apply to all models.



---

## CERTIFICATE No CF 689

### BOSS DOOR CONTROLS

---

**BOSS DOOR CLOSERS - TS1.203, TS4.224, TS5.224, TS5.224V, TS5.225, TS5.225DA, TS5.225SA & TS5.226**

3. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
4. The closers are approved on the basis of:
  - i) Initial type testing to EN1154 and BS EN 1634-1.
  - ii) An appraisal against TS34
  - iii) Inspection of quality management system
  - iv) Inspection and surveillance of factory production control
  - v) Ongoing audit testing in accordance with EN 1154 requirements
5. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
6. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic-based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
7. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
8. The approval relates to on-going production. The product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

## CERTIFICATE No CF 689 BOSS DOOR CONTROLS

BOSS DOOR CLOSERS - TS1.203, TS4.224, TS5.224, TS5.224V, TS5.225, TS5.225DA, TS5.225SA & TS5.226

### 10. Matrix of acceptable doorsets for TS1.203, TS4.224, TS5.224V & TS5.225SA

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	x	x	✓	x	x
FD30	x	x	✓	x	x
FD60	x	x	✓	x	x
FD120	x	x	✓	x	x
FD240	x	x	x	x	x
E 20	x	x	✓	x	x
EI 20	x	x	✓	x	x
E 30	x	x	✓	x	x
EI 30	x	x	✓	x	x
E 60	x	x	✓	x	x
EI 60	x	x	✓	x	x
E 90	x	x	✓	x	x
EI 90	x	x	✓	x	x
E 120	x	x	✓	x	x
EI 120	x	x	✓	x	x
E 240	x	x	x	x	x
EI 240	x	x	x	x	x

**Key:**

- ✓ - Approved
- x - Not approved

## CERTIFICATE No CF 689 BOSS DOOR CONTROLS

**BOSS DOOR CLOSERS - TS1.203, TS4.224, TS5.224, TS5.224V, TS5.225, TS5.225DA, TS5.225SA & TS5.226**

12. The following tables show acceptable doorsets types and fire resistance periods:

**Matrix of acceptable doorsets for TS5.224, TS5.225, TS5.225DA & TS5.226**

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	✓*	✓*	✓	✗	✗
FD30	✓*	✓*	✓	✗	✗
FD60	✓*	✓*	✓	✗	✗
FD120	✓*	✓*	✓	✗	✗
FD240	✓*	✓*	✗	✗	✗
E 20	✗	✗	✓	✗	✗
EI 20	✓*	✓*	✓	✗	✗
E 30	✗	✗	✓	✗	✗
EI 30	✓*	✓*	✓	✗	✗
E 60	✗	✗	✓	✗	✗
EI 60	✓*	✓*	✓	✗	✗
E 90	✗	✗	✓	✗	✗
EI 90	✓*	✓*	✓	✗	✗
E 120	✗	✗	✓	✗	✗
EI 120	✓*	✓*	✓	✗	✗
E 240	✗	✗	✗	✗	✗
EI 240	✓*	✓*	✗	✗	✗

**Key:**

- ✓ - Approved
- ✗ - Not approved
- ✓\* - Fully-insulated steel-based doorsets only

## CERTIFICATE No CF 689 BOSS DOOR CONTROLS

**BOSS DOOR CLOSERS - TS1.203, TS4.224, TS5.224, TS5.224V, TS5.225, TS5.225DA, TS5.225SA & TS5.226**

13. Doors are classified as the following types:

**Type MM** - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

**Type IMM** - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

**Type ITT** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

**Type ITM** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

**Type ITC** - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

**Classification codes** - The approval provides the following classifications:

TS1.203 in projecting arm configuration (Figure 1):

4	8	3	1	1	3
---	---	---	---	---	---

TS4.224 in projecting arm (Figure 1) configuration:

4	8	3	1	1	3
---	---	---	---	---	---

TS4.224 in parallel arm (Figure 6) configuration:

3	8	3	1	1	3
---	---	---	---	---	---

TS5.224 in projecting arm configuration (Figure 1):

4	8	4 2	1	1	3
---	---	--------	---	---	---

TS5.224 in parallel arm configuration (Figure 6):

3	8	4	1	1	3
---	---	---	---	---	---

## CERTIFICATE No CF 689 BOSS DOOR CONTROLS

BOSS DOOR CLOSERS - TS1.203, TS4.224, TS5.224, TS5.224V, TS5.225, TS5.225DA, TS5.225SA & TS5.226

### Classification codes – Continued

TS5.224V in projecting arm configuration (Figure 1):

4	8	4 2	1	1	3
---	---	--------	---	---	---

TS5.224V in parallel arm configuration (Figure 6):

3	8	4 3	1	1	3
---	---	--------	---	---	---

TS5.225 in projecting arm configuration (Figure 1):

4	8	5 2	1	1	3
---	---	--------	---	---	---

TS5.225 in parallel arm configuration (Figure 6):

3	8	5 2	1	1	3
---	---	--------	---	---	---

TS5.225DA in projecting arm configuration (Figure 1):

4	8	5 2	1	1	3
---	---	--------	---	---	---

TS5.225SA in sliding arm configuration (Body door mounted on pull face):

3	8	4 2	1	1	3
---	---	--------	---	---	---

TS5.225SA in sliding arm configuration (Body transom mounted on push face):

3	8	3 2	1	1	3
---	---	--------	---	---	---

TS5.226 in projecting arm configuration (Figure 1):

4	8	6 3	1	1	3
---	---	--------	---	---	---

TS5.226 in parallel arm configuration (Figure 6):

3	8	5 3	1	1	3
---	---	--------	---	---	---

*Note: power ratings shall be appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).*

## CERTIFICATE No CF 689 BOSS DOOR CONTROLS

**BOSS DOOR CLOSERS - TS1.203, TS4.224, TS5.224, TS5.224V, TS5.225, TS5.225DA, TS5.225SA & TS5.226**

**Scope of Approval:**

- Doors may not include uninsulated glass above 20% of their total area. Uninsulated glass shall not be included directly beneath the door closer body
- All closer models are only approved in the fitting applications detailed with their classification codes.
- The closers may not be fitted to timber doorsets without perimeter intumescent fire seals to the frame rebate or door edge.
- Closers TS5.224, TS5.225, TS5.225DA & TS5.226 are only approved for use on steel-based doorsets that are fully-insulated for the required classification period.
- Mechanical Hold open option is not approved.
- The following functions are supported by this certification:

Closer Ref.	Configuration	Backcheck	Delayed-Action
TS5.225	Fig. 1	✓	✗
TS5.225	Fig. 6	✗	✗
TS5.224	Fig. 1	✗	✗
TS5.224	Fig. 6	✓	✗
TS4.224	Fig. 1	✗	✗
TS4.224	Fig. 6	✗	✗
TS1.203	Fig. 1	✗	✗
TS5.224V	Fig. 1	✓	✗
TS5.224V	Fig. 6	✗	✗
TS5.225DA	Fig. 1	✗	✓
TS5.226	Fig. 1	✓	✗
TS5.226	Fig. 6	✗	✗
TS5.225SA	Body door mounted on pull face	✗	✗
TS5.225SA	Body transom mounted on push face	✗	✗





---

## CERTIFICATE No CF 689

### BOSS DOOR CONTROLS

---

**BOSS DOOR CLOSERS - TS1.203, TS4.224, TS5.224, TS5.224V, TS5.225, TS5.225DA, TS5.225SA & TS5.226**

#### Further Information

Further information regarding the details contained in this data sheet may be obtained from Boss Door Controls (Tel: 01506 467477).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 9 of 9 Signed  
J/010

Issued: 21<sup>st</sup> May 2009  
Reissued: 3<sup>rd</sup> July 2020  
Valid to: 2<sup>nd</sup> July 2025