

CERTIFICATE OF APPROVAL No CS 5111

This is to certify that, in accordance with
STS200 General Requirements for Certification of Enhanced Security Products
The undermentioned products of

LATHAM'S SECURITY DOORSETS LTD

35/37 Hainge Road, Tividale, West Midlands, B69 2NY
Tel: 01385 220 050

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:


CERTIFIED PRODUCT
70mm Steel High Security Doorset

TECHNICAL SCHEDULE
STS202 - Requirements for burglary
resistance of construction products

CLASSIFICATION			
Security	Weather	Strength	Material Specific
STS202 BR3	BS6375-1 800U	BS6375-2&3 Medium Duty	NPD

NPD = No performance determined

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited



Paul Duggan
Certification Manager



Issued:
Audit Test Frequency
Valid to:

26th June 2020
Annually
25th June 2025



CERTIFICATE No CS 5111 LATHAMS SECURITY DOORSETS LTD

Latham's Security Doorsets Ltd – 70mm Steel High Security Doorset

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of the above in providing a burglar resistance to STS 202: Issue 8: February 2019 level BR3, a weather performance of 800U to BS6375-1:2015, a mechanical strength performance of Medium Duty to BS6375-2:2009 and an additional performance to BS6375-3 Annex A & C.
3. The doorsets are approved on the basis of:
 - i. Initial type testing against STS202 & BS6375. Element Wednesbury test reports WIL 420673-1, WIL 420673-2, WIL 422056 & WIL 422401
 - ii. Audit testing at the frequency specified in STS 200 & STS 202 where relevant.
 - iii. A design appraisal against STS202 where relevant.
4. Inspection and surveillance of factory production control at Latham's Security Doorsets Ltd, 35/37 Hainge Road, Tividale, West Midlands, B69 2NY and Chongqing Mexin Best Doors & Windows Industry Co. Ltd, No. 56 Baihe Road, Nanping Economy & Technology Developing District, Chongqing, China
5. This approval is applicable to complete doorsets only.
6. This certification is designed to demonstrate compliance of the doorset specifically with STS202 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
7. This approval is applicable to single-leaf, unglazed, open-in & open-out doorsets without sidelights & toplights, without letterplates at leaf dimensions up to those given in Table 1.
8. Approved hardware items are:
 - 4no. Chongqing Number One Technology Co. Ltd Ball Bearing Butt hinges. MX-JL4.5*4.5# with 4no. Chongqing Mexin Best Doors & Windows Industry Co. Ltd Anti-jimmy bolt. Ref: MX-FJX01#
 - Zhejiang Hongli Locks Co., Ltd. HL33# Multipoint sash lock & B03 sidelock
 - Zhejiang Hongli Locks Co. Ltd Stainless steel lever handles 918902
 - UAP Limited 3* Kinetica cylinder 95mm in length KM50EX/35NAS

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

CERTIFICATE No CS 5111 LATHAMS SECURITY DOORSETS LTD

Latham's Security Doorsets Ltd – 70mm Steel High Security Doorset

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)	Door leaf thickness (mm)
Open-in & open-out, single-leaf only.	1132	2055	70

Table 1. Permitted Door Leaf Dimensions

Configuration	Maximum frame width (mm)	Maximum frame height (mm)
Single leaf without toplights or sidelights	1195	2100

Table 2. Permitted Frame Dimensions

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

- The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
- Labels to the CERTISECURE design referencing CERTISECURE, STS202 BR3, Latham's Security Doorsets, and CERTISECURE certificate No. CS 5111 shall be affixed to each doorset in the prescribed position.
- This approval relates to on going production. The doorset and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

Further Information

Further information regarding the details contained in this report may be obtained from Latham's Security Doorsets Ltd 35/37 Hainge Road, Tividale, West Midlands, B69 2NY (Tel: 01385 220 050)

Further information regarding CERTISECURE certification and other approved products can be obtained from WarringtonFire Certification Limited, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646777).